

Details of Future Fire Alarm Control Panel System : ANNEXURE - B

SI No	Details of Future Fire Alarm Control Panel System in Annexure B	AREA	Type of System	Method of Testing	Multi detectors (Nos)	Smoke Detectors (Nos)	Manual Call Points (Nos)	Beam Detector (Nos)	Duct Detectors (Nos)	Sounders (Nos)	Response Indicators (Nos)
1	Advanced Polymers and Materials Research Facility	VRC	Addressable	Aerosol/Agarbatti	53	-	5	-	1	6	21
2	Advanced Chemical Technology Activities	PFC	Addressable	Aerosol	42	-	6	-	1	5	29
3	Bonded Stores For Composite Materials	VKC	Addressable	Aerosol/Agarbatti	27	-	8	2	-	8	8
4	Augumentation of STF at RSTD & RVTG	TERLS	Addressable	Aerosol	36	-	13	-	1	13	12
5	Transport Complex	TERLS	Addressable	Agarbatti	25	-	3	-	-	4	-
6	Advanced Special Coating Processing and Characterisation Facility	RFF	Addressable	Agarbatti	8	-	2	-	-	3	2
7	Screening of Electronic Components for QDAC	VRC	Addressable	Aerosol	42	-	5	-	-	4	18
8	New Office Building for Stores and Purchase	RFF	Addressable	Agarbatti	55	-	8	-	-	5	24
9	Additive Manufacturing Facility	RFF	Addressable	Agarbatti	24	-	8	7	-	6	11
10	Building for Housing CNC-VTMC machine	TERLS	Addressable	Agarbatti	16	-	3	3	-	4	8
11	Ablative Production facility (GOCO)	TERLS	Addressable	Agarbatti	-	41	3	13	-	3	2
12	Management Admin Block	TERLS	Addressable	Agarbatti	-	96	3	-	2	-	-
13	Machining and Assembly Builidng	TERLS	Addressable	Agarbatti	-	61	3	-	-	-	-
14	Substation for GOCO facilities	TERLS	Addressable	Agarbatti	-	26	1	9	-	2	-
15	Photo Fabrication Shop	TERLS	Addressable	Agarbatti	20	-	5	-	1	5	7
16	Horizontal Extension of Akshaya Builidng	VRC	Conventional	Agarbatti	6	-	1	-	2	1	-
17	Gaganyaan CES motor Facility	TERLS	Addressable	Agarbatti	9	-	7	3	-	5	2
18	Fire control room	CMSE	Addressable	Agarbatti	-	78	13	6	-	18	-
19	CAB building	CMSE	Addressable	Agarbatti	-	39	7	-	-	7	-
20	C- BlocK	IISU	Addressable	Agarbatti	-	50	2	-	-	2	20
21	E Block	IISU	Addressable	Agarbatti	-	117	6	1	-	5	10
22	Nozzle Building	CMSE	Addressable	Agarbatti	-	62	17	13	-	24	-
23	QDC	CMSE	Addressable	Agarbatti	-	149	17	-	-	34	-
24	Pyro Devices Assembly	TERLS	Addressable	Aerosol	-	110	3	4	-	-	-
25	Test Control Building	TERLS	Addressable	Aerosol	-	135	16	8	-	5	72
26	Space Museum	TERLS	Addressable	Aerosol	77	-	6	-	6	7	36
27	Lithium ion Facility	INSTEF	Conventional	Aerosol	3	-	1	-	3	2	-
28	Augumentation of VRC main building (Ph-II)	VRC	Addressable	Agarbatti	110	-	8	1	3	6	53
29	Hydraulic Pressure Test facility	TERLS	Addressable	Agarbatti	63	-	11	2	-	3	32
30	SEMI-PERMANENT AUDITORIUM OF VSSC CENTRAL SCHOOL	TERLS	Conventional	Agarbatti	10	-	3	1	-	3	-
* There will be 10% variation in the quantity of devices mentioned here depending on the site conditions.											