

Compliance Matrix to be filled up by vendor

Sr. No.	Specification	Specification-Value	Specification-value offered by Vendor	Compliance by Vendor (in Yes/No format only)
General Specifications				
1	Supply	Vendor shall ensure safe delivery of the products along with necessary accessories.		
2	Warranty	The products delivered shall have warranty of 1 year from the date of delivery. The warranty shall cover material/performance defects.		
3	Evaluation Criteria	Indent of single Item, L1 basis		
4	Confirmation of Compliance Matrix	Vendor is required to submit confirmation of compliance matrix at the time of submitting quote. (Blank document is attached along with indent)		
5	Delivery Time	Products to be delivered within 6 weeks from release of PO		
Item: CLEAN ROOM MATERIALS - Sterile Garment Storage Cabinet				
1	Material	Stainless steel (SS 304)		
2	Cleanliness Level	Class 1000 (ISO Class) or better		
3	Airflow	Vertical or Horizontal recirculatory air flow with positive pressure, HEPA filter and blower assembly		
4	High Efficiency Particulate Air - HEPA filter efficiency	99.99% or better at 0.3 microns		
5	Pre-filter efficiency	75% or better at 5 microns		
6	Shelving and Storage	Hanging Rods, Fixed shelves		
7	Doors	Two-sided opening		
8	Illumination	LED lighting		
9	UV light	For additional disinfection, safety interlocking to prevent exposure when doors are opened		
10	Differential Pressure Gauge	To check the pressure drop across HEPA filter		
11	Blower motor assembly	Electric motor single phase		
12	Power supply	220V AC, 50Hz		
13	Compatibility	Product should be functionally compatible with fully covered directions of left, right, back, top		
14	Duct mounting available for Inlet & Outlet air flow	Front Only		
15	Overall Width	925mm (+/- 5mm)		
16	Overall Depth	550mm (+/- 50mm)		
17	Overall Height	1750mm (+/- 50mm)		