

Parameter	Specification
Flame proof hooter cum flasher	Should be possible to interface with the Oxygen detector
Input power to Hooter cum flasher	24 V dc preferable
Minimum audible distance	It shall be Clearly audible /visible for a minimum of 150 metres